



شهادة مطابقة CERTIFICATE OF CONFORMITY

Certificate Number:	25-04-146156/E25-03-150678/NB0007	رقم الشهادة:
Registration Date:	09/04/2025	تاريخ التسجيل:
Valid Until:	08/04/2026	صالحة لغاية:
Issued To:	BAINUNA MECHANICAL ELECTRICAL EQUIPMENT AND OIL FIELD SERVICES أبو ظبي - شارع حمدان بن محمد - بناية ورثة / ناصر, P.O. Box 642 بن مذكر آل شافي الهاجري - شارع حمدان بن محمد - بناية ورثة / Abu Dhabi ناصر بن مذكر آل شافي الهاجري	أصدرت إلى:
Sector:	Electrical	قطاع: كهرباء
Product Category:	ECAS-Ex	تصنيف المنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار
Product Sub-Category:	ECAS-Ex	التصنيف الفرعي للمنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار

Please check Schedule of certification for all product details يرجى التحقق من بيان التسجيل المرفق لجميع تفاصيل المنتجات

intertek
Total Quality. Assured.
جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



Products are registered under the Emirates Conformity Assessment Scheme (ECAS) based on compliance to the Approved Standards المنتجات مسجلة في نظام تقويم المطابقة الإماراتي (إيكاس) بناء على مطابقتها للمواصفات المعتمدة

600565554

www.moiat.gov.ae

@MoIAT



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
This document has been issued electronically and doesn't require a stamp and signature.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

Company Name: BAINUNA MECHANICAL ELECTRICAL EQUIPMENT AND OIL FIELD SERVICES **اسم الشركة:**

Product Category: ECAS-Ex **تصنيف المنتج:** الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار

Certificate No.: 25-04-146156/E25-03-150678/NB0007 **رقم التسجيل:**

Registration Date: 09/04/2025 **تاريخ التسجيل:**

Valid Until: 08/04/2026 **صالح لغاية:**

Sr.No.	الاسم التجاري Brand Name	رقم الموديل Model Number	تفاصيل المنتج Product Details	تصنيف النجوم Star Rating	الأبعاد/الحجم Dimension/ Size	التقارير Reports	المواصفات المطبقة Applicable Standards	بلد المنشأ Country Of Origin
--------	-----------------------------	-----------------------------	----------------------------------	-----------------------------	----------------------------------	---------------------	---	---------------------------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

1	Thermo Engineering s.r.l.	111TE02	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEx INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
---	---------------------------	---------	--	-----	----	--	--	-------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

2	Thermo Engineering s.r.l.	111TE03	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
---	---------------------------	---------	--	-----	----	--	--	-------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

3	Thermo Engineering s.r.l.	111TE04	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEx INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
---	---------------------------	---------	--	-----	----	--	--	-------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

4	Thermo Engineering s.r.l.	111TE05	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
---	---------------------------	---------	--	-----	----	--	--	-------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

5	Thermo Engineering s.r.l.	111TE06	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
---	---------------------------	---------	--	-----	----	--	--	-------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

6	Thermo Engineering s.r.l.	111TE07	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEx INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
---	---------------------------	---------	--	-----	----	--	--	-------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

7	Thermo Engineering s.r.l.	111TE08	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
---	---------------------------	---------	--	-----	----	--	--	-------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

8	Thermo Engineering s.r.l.	111TE09	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
---	---------------------------	---------	--	-----	----	--	--	-------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

9	Thermo Engineering s.r.l.	111TE10	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEx INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
---	---------------------------	---------	--	-----	----	--	--	-------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

10	Thermo Engineering s.r.l.	111TE11	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
----	---------------------------	---------	--	-----	----	--	--	-------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

11	Thermo Engineering s.r.l.	111TE12	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
----	---------------------------	---------	--	-----	----	--	--	-------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

12	Thermo Engineering s.r.l.	111TE13	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C, T100°C, T135°C or T200°C Db IP66 or IP68	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
----	---------------------------	---------	--	-----	----	--	--	-------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

13	Thermo Engineering s.r.l.	112TE02	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
14	Thermo Engineering s.r.l.	112TE03	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

15	Thermo Engineering s.r.l.	112TE04	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
16	Thermo Engineering s.r.l.	112TE05	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

17	Thermo Engineering s.r.l.	112TE06	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
18	Thermo Engineering s.r.l.	112TE07	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

19	Thermo Engineering s.r.l.	112TE08	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
20	Thermo Engineering s.r.l.	112TE09	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

21	Thermo Engineering s.r.l.	112TE10	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
22	Thermo Engineering s.r.l.	112TE11	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.

This document has been issued electronically and doesn't require a stamp and signature.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

23	Thermo Engineering s.r.l.	112TE12	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da	N/A	NA	IECEx INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR/19.0014/04	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-11, UAE.S IEC 60079-31	ITALY
Nothing Follows								



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology

