



شهادة مطابقة CERTIFICATE OF CONFORMITY

Certificate Number:	26-06-198615/E26-06-208102/NB0007	رقم الشهادة:
Registration Date:	22/06/2026	تاريخ التسجيل:
Valid Until:	21/06/2029	صالحة لغاية:
Issued To:	THERMO ENGINEERING S.r.l. P.O. Box 26030 ,Malagnino (CR) Via Giuseppina 19 ,ITALY	أصدرت إلى :
Sector:	Electrical	قطاع: كهرباء
Regulation:	ECAS-Ex	اللائحة: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار
Product Category:	ECAS-Ex	التصنيف: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار
Product Sub-Category:	ECAS-Ex	التصنيف الفرعي للمنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار

Please check Schedule of certification for all product details يرجى التحقق من بيان التسجيل المرفق لجميع تفاصيل المنتجات



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



Products are registered under the Emirates Conformity Assessment Scheme (ECAS) based on compliance to the Approved Standards

المنتجات مسجلة في نظام تقويم المطابقة الإماراتي (إيكاس) بناء على مطابقتها للمواصفات المعتمدة

600565554

www.moiat.gov.ae

@MoIAT



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

Company Name:	THERMO ENGINEERING S.r.l.	اسم الشركة:
Product Category:	ECAS-Ex	تصنيف المنتج:
Certificate No.:	26-06-198615/E26-06-208102/NB0007	رقم التسجيل:
Registration Date:	22/06/2026	تاريخ التسجيل:
Valid Until:	21/06/2029	صالح لغاية:

Sr.No.	الاسم التجاري Brand Name	رقم الموديل Model Number	تفاصيل المنتج Product Details	تصنيف النجوم Star Rating	الأبعاد/الحجم Dimension/ Size	التقارير Reports	المواصفات المطبقة Applicable Standards	بلد المنشأ Country Of Origin
1	Thermo Engineering S.r.l.	TE-TSTTE01	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE 12.0001U Issue 02 for model details	N/A	NA	IECEx INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
2	Thermo Engineering S.r.l.	TE-TSTTE02	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66;	N/A	NA	IECEx INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			refer to IECEx IEC 12.0001U Issue 02 for model details				60079-1, UAE.S IEC 60079-31	
3	Thermo Engineering S.r.l.	TE-TSTTE03	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIC Db IP66; refer to IECEx IEC 12.0001U Issue 02 for model details	N/A	NA	IECEx IEC 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
4	Thermo Engineering S.r.l.	TE-TSTTE04	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIC Db IP66; refer to IECEx IEC 12.0001U Issue 02 for model details	N/A	NA	IECEx IEC 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
5	Thermo Engineering S.r.l.	TE-TSTTE05	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIC Db IP66; refer to IECEx IEC 12.0001U Issue 02 for model details	N/A	NA	IECEx IEC 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

6	Thermo Engineering S.r.l.	TE-TSTTE06	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE 12.0001U Issue 02 for model details	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
7	Thermo Engineering S.r.l.	TE-TSTTE07	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE 12.0001U Issue 02 for model details	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
8	Thermo Engineering S.r.l.	TE-TSTTE08	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE 12.0001U Issue 02 for model details	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
9	Thermo Engineering S.r.l.	TE-TSTTE09	Connection head type TST; Type of Protection: db and tb ;	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01	UAE.S IEC 60079-0,	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE 12.0001U Issue 02 for model details			FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-1, UAE.S IEC 60079-31	
10	Thermo Engineering S.r.l.	TE- TSTTE10	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE 12.0001U Issue 02 for model details	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
11	Thermo Engineering S.r.l.	TE- TSTTE11	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE 12.0001U Issue 02 for model details	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
12	Thermo Engineering S.r.l.	TE- TSTTE12	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae

بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			12.0001U Issue 02 for model details				IEC 60079-31	
13	Thermo Engineering S.r.l.	TE-TSTTE13	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE 12.0001U Issue 02 for model details	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
14	Thermo Engineering S.r.l.	TE-TSTTE14	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE 12.0001U Issue 02 for model details	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
15	Thermo Engineering S.r.l.	TE-TSTTE15	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEx INE 12.0001U Issue 02 for model details	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
16	Thermo	TE-	Connection head type	N/A	NA	IECEX INE 12.0001U	UAE.S	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

	Engineering S.r.l.	TSTTE16	TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEX INE 12.0001U Issue 02 for model details			FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	
17	Thermo Engineering S.r.l.	TE-TSTTE17	Connection head type TST; Type of Protection: db and tb ; Marking: Ex db IIC Gb, Ex tb IIIC Db IP66; refer to IECEX INE 12.0001U Issue 02 for model details	N/A	NA	IECEX INE 12.0001U FR/INE/ExTR12.0001/01 FR/INE/ExTR12.0001/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
18	Thermo Engineering S.r.l.	111TE01	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			IECEX INE 12.0032X Issue 04 for specific model details				IEC 60079-31	
19	Thermo Engineering S.r.l.	111TE02	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
20	Thermo Engineering S.r.l.	111TE03	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEX INE 12.0032X Issue 04 for specific model details				60079-1, UAE.S IEC 60079-31	
21	Thermo Engineering S.r.l.	111TE04	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
22	Thermo Engineering S.r.l.	111TE05	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C,	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEx IEC 12.0032X Issue 04 for specific model details				60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	
23	Thermo Engineering S.r.l.	111TE06	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEx IEC 12.0032X Issue 04 for specific model details	N/A	NA	IECEx IEC 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
24	Thermo Engineering S.r.l.	111TE07	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC	N/A	NA	IECEx IEC 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEx IEC 12.0032X Issue 04 for specific model details				60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	
25	Thermo Engineering S.r.l.	111TE08	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEx IEC 12.0032X Issue 04 for specific model details	N/A	NA	IECEx IEC 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
26	Thermo Engineering	111TE09	Thermometric Probe; Type of Protection:db,	N/A	NA	IECEx IEC 12.0032X FR/INE/ExTR12.0031/03	UAE.S IEC	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

	S.r.l.		ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEx INE 12.0032X Issue 04 for specific model details			FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	
27	Thermo Engineering S.r.l.	111TE10	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEx INE 12.0032X	N/A	NA	IECEx INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae

بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Issue 04 for specific model details					
28	Thermo Engineering S.r.l.	111TE11	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEx INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
29	Thermo Engineering S.r.l.	111TE12	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C,	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1,	ITALY



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			T135°C or T200°C Db IP66 or IP68; refer to IECEX INE 12.0032X Issue 04 for specific model details				UAE.S IEC 60079-31	
30	Thermo Engineering S.r.l.	111TE13	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex db IIC T6, T5, T4 or T3 Ga/Gb or Gb Ex ta IIIC T85°C, T100°C, T135°C or T200°C Da / Ex tb IIIC T85°C, T100°C, T135°C or T200°C Db IP66 or IP68 or Ex tb III C T85°C T100°C, T135°C or T200°C Db IP66 or IP68; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
31	Thermo Engineering S.r.l.	112TE01	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEX INE 12.0032X	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0,	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Issue 04 for specific model details				UAE.S IEC 60079-1, UAE.S IEC 60079-31	
32	Thermo Engineering S.r.l.	112TE02	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
33	Thermo Engineering S.r.l.	112TE03	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEX INE 12.0032X	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Issue 04 for specific model details				IEC 60079-1, UAE.S IEC 60079-31	
34	Thermo Engineering S.r.l.	112TE04	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEx INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
35	Thermo Engineering S.r.l.	112TE05	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEx INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

							60079-1, UAE.S IEC 60079-31	
36	Thermo Engineering S.r.l.	112TE06	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
37	Thermo Engineering S.r.l.	112TE07	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1,	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

							UAE.S IEC 60079-31	
38	Thermo Engineering S.r.l.	112TE08	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
39	Thermo Engineering S.r.l.	112TE09	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

							IEC 60079-31	
40	Thermo Engineering S.r.l.	112TE10	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
41	Thermo Engineering S.r.l.	112TE11	Thermometric Probe; Type of Protection:db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

							IEC 60079-31	
42	Thermo Engineering S.r.l.	112TE12	Thermometric Probe; Type of Protection: db, ta, tb, ia; Marking: Ex ia IIC T6, T5, T4 or T3 Ga/Gb or Ga and Ex ia IIC T85°C, T100°C, T135°C or T200°C Da/Db or Da; refer to IECEX INE 12.0032X Issue 04 for specific model details	N/A	NA	IECEX INE 12.0032X FR/INE/ExTR12.0031/03 FR/INE/ExTR12.0031/04 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	ITALY
43	Thermo Engineering S.r.l.	113TE01	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ma": Ex ma IIC T6, T5, T4 Ga Ex ma IIC T85°C, T100°C, T135°C Da IP66; refer to IECEX INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
44	Thermo Engineering	113TE02	Temperature probe; Type of Protection: "ia"	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02	UAE.S IEC	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

	S.r.l.		and "ma" ; Marking: For the Type of Protection "ma": Ex ma IIC T6, T5, T4 Ga Ex ma IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details			DE/TUR/QAR19.0014/05	60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	
45	Thermo Engineering S.r.l.	113TE03	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ma": Ex ma IIC T6, T5, T4 Ga Ex ma IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEx INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
46	Thermo Engineering S.r.l.	113TE04	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ma": Ex ma IIC T6, T5, T4 Ga Ex ma IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx	N/A	NA	IECEx INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			INE 12.0046X Issue 02 for specific model details					
47	Thermo Engineering S.r.l.	113TE05	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ma": Ex ma IIC T6, T5, T4 Ga Ex ma IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
48	Thermo Engineering S.r.l.	113TE06	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ma": Ex ma IIC T6, T5, T4 Ga Ex ma IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
49	Thermo Engineering S.r.l.	113TE07	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S	ITALY



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Protection "ma": Ex ma IIC T6, T5, T4 Ga Ex ma IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details				IEC 60079-11, UAE.S IEC 60079-0	
50	Thermo Engineering S.r.l.	113TE08	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ma": Ex ma IIC T6, T5, T4 Ga Ex ma IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
51	Thermo Engineering S.r.l.	113TE09	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ma": Ex ma IIC T6, T5, T4 Ga Ex ma IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			02 for specific model details					
52	Thermo Engineering S.r.l.	113TE10	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ma": Ex ma IIC T6, T5, T4 Ga Ex ma IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
53	Thermo Engineering S.r.l.	114TE01	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
54	Thermo Engineering S.r.l.	114TE02	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11,	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx IEC 12.0046X Issue 02 for specific model details				UAE.S IEC 60079-0	
55	Thermo Engineering S.r.l.	114TE03	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx IEC 12.0046X Issue 02 for specific model details	N/A	NA	IECEx IEC 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
56	Thermo Engineering S.r.l.	114TE04	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx IEC 12.0046X Issue 02 for specific model details	N/A	NA	IECEx IEC 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
57	Thermo Engineering S.r.l.	114TE05	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of	N/A	NA	IECEx IEC 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details				IEC 60079-11, UAE.S IEC 60079-0	
58	Thermo Engineering S.r.l.	114TE06	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
59	Thermo Engineering S.r.l.	114TE07	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
60	Thermo Engineering	114TE08	Temperature probe; Type of Protection: "ia"	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02	UAE.S IEC	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقمياً عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

	S.r.l.		and "ma" ; Marking: For the Type of Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details			DE/TUR/QAR19.0014/05	60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	
61	Thermo Engineering S.r.l.	114TE09	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEx INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
62	Thermo Engineering S.r.l.	114TE10	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEx INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEx INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

63	Thermo Engineering S.r.l.	114TE11	Temperature probe; Type of Protection: "ia" and "ma" ; Marking: For the Type of Protection "ia": Ex ia IIC T6, T5, T4 Ga, Ex ia IIIC T85°C, T100°C, T135°C Da IP66; refer to IECEX INE 12.0046X Issue 02 for specific model details	N/A	NA	IECEX INE 12.0046X FR/INE/ExTR12.0045/02 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-18, UAE.S IEC 60079-11, UAE.S IEC 60079-0	ITALY
64	Thermo Engineering S.r.l.	215TE01	Temperature probe; Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIC T6, T5, T4 Ga, Ex ec IIC T6, T5, T4 Gc, Ex ia IIIC T85°C, T100°C, T135°C Da IP66/IP67 Ex tc IIIC T85°C, T100°C, T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	ITALY
65	Thermo Engineering S.r.l.	215TE02	Temperature probe; Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIC T6, T5, T4 Ga, Ex	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			ec IIC T6,T5,T4 Gc, Ex ia IIIC T85°C,T100°C,T135°C Da IP66/IP67 Ex tc IIIC T85°C,T100°C,T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details				60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	
66	Thermo Engineering S.r.l.	215TE03	Temperature probe;Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIC T6,T5,T4 Ga, Ex ec IIC T6,T5,T4 Gc, Ex ia IIIC T85°C,T100°C,T135°C Da IP66/IP67 Ex tc IIIC T85°C,T100°C,T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	ITALY
67	Thermo Engineering S.r.l.	215TE04	Temperature probe;Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIC T6,T5,T4 Ga, Ex ec IIC T6,T5,T4 Gc, Ex	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-0,	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			ia IIIC T85°C,T100°C,T135°C Da IP66/IP67 Ex tc IIIC T85°C,T100°C,T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details				UAE.S IEC 60079-7, UAE.S IEC 60079-31	
68	Thermo Engineering S.r.l.	215TE05	Temperature probe;Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIIC T6,T5,T4 Ga, Ex ec IIIC T6,T5,T4 Gc, Ex ia IIIC T85°C,T100°C,T135°C Da IP66/IP67 Ex tc IIIC T85°C,T100°C,T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	ITALY
69	Thermo Engineering S.r.l.	215TE06	Temperature probe;Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIIC T6,T5,T4 Ga, Ex ec IIIC T6,T5,T4 Gc, Ex ia IIIC	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-0, UAE.S	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			T85°C,T100°C,T135°C Da IP66/IP67 Ex tc IIIC T85°C,T100°C,T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details				IEC 60079-7, UAE.S IEC 60079-31	
70	Thermo Engineering S.r.l.	215TE07	Temperature probe;Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIC T6,T5,T4 Ga, Ex ec IIC T6,T5,T4 Gc, Ex ia IIIC T85°C,T100°C,T135°C Da IP66/IP67 Ex tc IIIC T85°C,T100°C,T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	ITALY
71	Thermo Engineering S.r.l.	215TE08	Temperature probe;Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIC T6,T5,T4 Ga, Ex ec IIC T6,T5,T4 Gc, Ex ia IIIC T85°C,T100°C,T135°C	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-0, UAE.S IEC	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Da IP66/IP67 Ex tc IIIC T85°C,T100°C,T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details				60079-7, UAE.S IEC 60079-31	
72	Thermo Engineering S.r.l.	215TE09	Temperature probe;Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIC T6,T5,T4 Ga, Ex ec IIC T6,T5,T4 Gc, Ex ia IIIC T85°C,T100°C,T135°C Da IP66/IP67 Ex tc IIIC T85°C,T100°C,T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	ITALY
73	Thermo Engineering S.r.l.	215TE10	Temperature probe;Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIC T6,T5,T4 Ga, Ex ec IIC T6,T5,T4 Gc, Ex ia IIIC T85°C,T100°C,T135°C Da IP66/IP67 Ex tc	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-0, UAE.S IEC 60079-7,	ITALY



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على
selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			IIIC T85°C,T100°C,T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details				UAE.S IEC 60079-31	
74	Thermo Engineering S.r.l.	215TE11	Temperature probe;Type of Protection: Ex ia, Ex ec, Ex tc ; Marking: Ex ia IIC T6,T5,T4 Ga, Ex ec IIC T6,T5,T4 Gc, Ex ia IIIC T85°C,T100°C,T135°C Da IP66/IP67 Ex tc IIIC T85°C,T100°C,T135°C Dc IP66/IP67; refer to IECEX TUR 20.0085X Issue 0 for specific model details	N/A	NA	IECEX TUR 20.0085X DE/TUR/ExTR20.0085/00 DE/TUR/QAR19.0014/05	UAE.S IEC 60079-11, UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	ITALY
Nothing Follows								



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
يمكن التحقق من المستند رقميا عبر بوابة UAE Pass Self-Care عن طريق رفع المستند على

selfcare.uaepass.ae

This document has been issued electronically and doesn't require a stamp and signature.

The document can be digitally verified via UAE Pass Self-Care portal by uploading the document to selfcare.uaepass.ae